

U-DESIGN for standard movements

PROCO Style 520 U-Type Fan/Duct Connectors: The most economical of the integrally flanged designs, the Style 520 is predominately used for fan vibration applications. The fan/duct connector is manufactured in a U-Design configuration with a minimum of one (1) to two (2) plies of reinforced fabric vulcanized into a homogeneous product that is 3/ 16", 1/4" or 3/8" thick. The Style 520 is manufactured with continuous corners. No splices will be made in the corner areas. Listed below is information regarding the Style 520 nonmetallic fan/duct connectors:

System Design Considerations: In designing the Series 500, Style 520 non-metallic fans/ duct connector, several considerations must be taken into account to ensure long lasting

- · System Media: The designer and/or requesting party should define the system media to determine the correct elastomer for each application. Evaluation of the gas/air composition should be made during design of the non-metallic fan/duct connector. Abrasion characteristics and external environment conditions should also be taken into account when specifying the fabric element.
- $\,$ System Temperature: The system operating temperature is of primary importance to the design of a non-metallic fan/duct connector, although the systemdesign is generally specified. It is important to distinguish between operating and design as "design" can include a significant safety factor which may result in an upgraded material or design
- System Pressure: Normal operating pressures and maximum pressures (positive and negative) under upset conditions should be specified. Combinations of pressures and temperatures should be specifically identified.
- Movements: Movements consist of thermal growth resulting from both operating and upset conditions. Individual movements resulting from both conditions should be specified. Maximum installation misalignment should also be taken into account to determine if the non-metallic fan/duct connector design is capable of reacting to a combination of the total maximum movements.

Style 520 Available Materials											
For Specific Elastomer Recommendations, See: PROCO™ "Chemical To Elastomer Guide"											
Styles	PROCO Material Code	Elastomer	Nominal Body Thickness	No. of Reinforcement Plies	Maximum Operating Temp °F	Maximum Pressure Rating (PSI)					
520	BB EE HH	Chlorobutyl EPDM Hypalon®	3/16"	1	300° 300° 225°	±2					
520	NH NN	Neoprene/Hypalon® Neoprene	1/4"	2	225° 212°	±3					
	NP VV	Neoprene/Buna-N Viton®	3/8"	2	212° 400°	±5					

- Hypalon and Viton are registered trademarks of DuDont Dow Elastomers
 Expansion Joint "Cover" (outside) can be Hypalon painted on special order.
 Standard fabric reinforcement is polyester. Other high temperature materials are available upon request. For vacuum applications, all fabric elements should retain sufficient setback from the duct to ensure that belting does not protrude into the flow stream.

	Non-Metallic Fan/Duct Connector Weight (pounds per square foot of periphery)											
Nominal				Elastomer	s			Retaining				
Body Thickness	Chloro- butyl	EPDM	Hypalon®	Neoprene/ Hypalon®	Neoprene	Neoprene/ Buna-N	Viton®	Rings/Bars Linear/Foot				
1/4"	1.6	1.6	1.8	1.8	1.8	1.8	2.5	3.5				
3/8"	3/8" 2.5 2.5 2.6 2.6 2.6 2.6											

Maximum Movement Capabilities											
6" Face To Face 9" Face To Face 12" Face To Face											
Axial Compression (Inches)	Axial Extension (Inches)	Lateral Offset (Inches)	Axial Compression (Inches)	Axial Extension (Inches)	Lateral Offset (Inches)	Axial Compression (Inches)	Axial Extension (Inches)	Lateral Offset (Inches)			
.75	.25	.50	1.25	.25	.75	2.0	.50	1.0			

NOTES: 1. Lateral Offsets shown above are based on movements prior to axial compression. Greater lateral offset may be obtained if the fan/duct connector encounters simultaneous compression.

obtained in the Individual Connection encounters simulatineous compression.

2. Axial extension may be increased by pre-compression of the fain/duct connector during installation, any pre-compression of the fan/duct connector will equally reduce the rated axial compression movement.

1/2" DIA. Fastners (By Others) Ducting Flange (By Others) Duct I.S. (I.D.) Pace To Face (F/F) "Neutral Installed"
* Holes ® 5/8" Dia. Round Flange Detail Flange O.D. * 4" Max. Spacing Recommended Bolt Circle
Rectangular Flange/ Corner Detail Hole Hole 1" Holes @ 5/8" Dia. * 4" max. Spacing Recommended

	Design Data She	et Fan/Duct Connector - Style 520
ltem	Tag No.:	
Ite	Quantity:	
u.	Equipment Adjacent The Connector:	
Application	Media: Gas or Air (circle one)	G A
Ap	Location of Joint: (Inlet, Discharge, Bypass)	
Size	Duct I.S. or Diameter:	
Si	Face To Face:	IN.
rature	Operating:	°F
Temperature	Design:	°F
Pressure	Operating:	PSI
Pres	Design:	PSI
ıts	Axial Compression:	IN.
Movements	Axial Extension:	IN.
Ž	Lateral Offset:	IN 1

01(xialal

ARCH-DESIGN for ultra high movements

PROCO Style 530 Arch-Type Duct Connectors: The least economical of the integrally flanged designs, the Style 530 is predominately used for applications where movements are large and face-to-face space is a premium. The duct connector is manufactured in an Arch-Design configuration with a minimum of one (1) to two (2) plies of reinforced fabric vulcanized into a homogeneous product that is 3/1/6", 1/4" or 3/8" thick. The flanges shall be an integral part of the expansion joint. The Style 530 is manufactured with a premolded arch. The arch continues through the corner and straight sections and shall be fully developed when in the neutral installation position. Listed below is information regarding the Style 530 non-metallic duct connectors:

System Design Considerations: In designing the Series 500, Style 530 non-metallic duct connector, several considerations must be taken into account to ensure long lasting service.

- · System Media: The designer and/or requesting party should define the system media to determine the correct elastomer for each application. Evaluation of the gas/air composition should be made during design of the non-metallic fan/duct connector. Abrasion characteristics and external environment conditions should also be taken into account when specifying the fabric element.
- System Temperature: The system operating temperature is of primary importance to the design of a non-metallic fan/duct connector, although the system design is generally specified. It is important to distinguish between operating and design as "design" can include a significant safety factor which may result in an upgraded material or design selection.
- System Pressure: Normal operating pressures and maximum pressures (positive and negative) under upset conditions should be specified. Combinations of pressures and temperatures should be specifically identified.
- Movements: Movements consist of thermal growth resulting from both operating and upset conditions. Individual movements resulting from both conditions should be specified. Maximum installation misalignment should also be taken into account to determine if the non-metallic fan/duct connector design is capable of reacting to a combination of the total maximum movements.

	Style 530 Available Materials										
For Specific Elastomer Recommendations, See: PROCO™ "Chemical To Elastomer Guide"											
Styles	Styles PROCO Nominal No. of Maximum Maximum Styles Material Elastomer Body Reinforcement Operating Pressure Code Thickness Plies Temp °F Rating (PSI)										
530	BB EE HH	Chlorobutyl EPDM Hypalon®	3/16"	1	300° 300° 225°	±2					
530	NH NN NP	Neoprene/Hypalon® Neoprene Neoprene/Buna-N	1/4" 3/8"	2	225° 212° 212°	±3 ±5					
	VV	Viton®			400°						

- NOTES: 1. Hypaion and Viton are registered trademarks of DuDont Dow Elastomers
 2. Expansion Joint "Cover" (outside) can be Hypaion painted on special order.
 3. Standard fabric reinforcement is polyester. Other high temperature materials are available upon request.
 4. For vacuum applications, all fabric elements should retain sufficient setback from the duct to ensure that belting does not protrude into the flow stream.

	Non-Metallic Fan/Duct Connector Weight (pounds per square foot of periphery)											
Nominal				Elastomer	s			Retaining				
Body Thickness	Chloro- butyl	EPDM	Hypalon®	Neoprene/ Hypalon®	Neoprene	Neoprene/ Buna-N	Viton®	Rings/Bars Linear/Foot				
1/4"	1.6	1.6	1.8	1.8	1.8	1.8	2.5	3.5				
3/8"	3/8" 2.5 2.5 2.6 2.6 2.6 2.6 4.8											

	Maximum Movement Capabilities										
6"	6" Face To Face 9" Face To Face 12" Face To Face										
Axial Compression (Inches) Axial Extension (Inches) Offset (Inches) Axial Compression (Inches) Axial Axial Axial Axial Axial (Inches) (Inches)						Axial Compression (Inches)	Axial Extension (Inches)	Lateral Offset (Inches)			
2.25	1.25	1.25	2.75	1.5	1.5	3.5	2.0	2.0			

NOTES: 1. Lateral Offsets shown above are based on movements prior to axial compression. Greater lateral offset may be

obtained if the fan/duct connector encounters simultaneous compression.

2. Axial extension may be increased by pre-compression of the fan/duct connector during installation. any pre-compression of the fan/duct connector will equally reduce the rated axial compression movement.

Series 530 Elastomer (By Others) Ducting Flange (By Others) Duct I.S. (i.D.) Face To Face (F/F) "Neutral installed"
* Holes @ 5/8" Dia. Round Flange Detail Flange O.D. * 4" Max. Spacing Recommended * Bolt Circle
Rectangular Flange/ Corner Detail First Hole 9 5/8" Dia. 1" First Hole 4" max. Spacing Recommended

	Design Data She	et Fan/Duct Connector - Style 530	
ltem	Tag No.:		
Ite	Quantity:		
u.	Equipment Adjacent The Connector:		
Application	Media: Gas or Air (circle one)	G A	
Ap	Location of Joint: (Inlet, Discharge, Bypass)		
Size	Duct I.S. or Diameter:		
Si	Face To Face:		IN.
rature	Operating:		°F
Temperature	Design:		°F
	Operating:		PSI
Pressure	Design:		PSI
ıts	Axial Compression:		IN.
Movements	Axial Extension:		IN.
Me	Lateral Offset:		IN.FÄ

W-DESIGN for maximum movements

PROCO Style 540 W-Type Duct Connectors: An economical integrally flanged design, the Style 540 is predominately used for applications where there are large movements. The duct connector is manufactured in a W-Design configuration with a minimum of one (1) to two (2) plies of reinforced fabric vulcanized into a homogeneous product that is 3/16", 1/ 4" or 3/8" thick. The flanges shall be an integral part of the expansion joint. The Style 540 is manufactured with a premolded arch. The arch continues through the corner and shall be fully developed when in the neutral position. Listed below are considerations regarding the design of the Style 540 non-metallic duct connectors:

System Design Considerations: In designing the Series 500, Style 540 non-metallic duct connector, several considerations must be taken into account to ensure long lasting service.

- · System Media: The designer and/or requesting party should define the system media to determine the correct elastomer for each application. Evaluation of the gas/air composition should be made during design of the non-metallic fan/duct connector. Abrasion characteristics and external environment conditions should also be taken into account when specifying the fabric element.
- System Temperature: The system operating temperature is of primary importance to the design of a non-metallic fan/duct connector, although the system design is generally specified. It is important to distinguish between operating and design as "design" can include a significant safety factor which may result in an upgraded material or de-
- System Pressure: Normal operating pressures and maximum pressures (positive and negative) under upset conditions should be specified. Combinations of pressures and temperatures should be specifically identified.
- Movements: Movements consist of thermal growth resulting from both operating and upset conditions. Individual movements resulting from both conditions should be specified. Maximum installation misalignment should also be taken into account to determine if the non-metallic fan/duct connector design is capable of reacting to a combination of the total maximum movements.

Style 540 Available Materials											
For Specific Elastomer Recommendations, See: PROCO™ "Chemical To Elastomer Guide"											
Styles Material Elastomer Body Reinforcement Operating Pressure Code Thickness Plies Temp °F Rating (PSI)											
F40	BB EE HH	Chlorobutyl EPDM Hypalon®	3/16"	1	300° 300° 225°	±2					
540	NH NN	Neoprene/Hypalon® Neoprene	1/4"	2	225° 212°	±3					
	NP VV	Neoprene/Buna-N Viton®	3/8"	2	212° 400°	±5					

- NOTES: 1. Hypaion and Viton are registered trademarks of DuDont Dow Elastomers
 2. Expansion Joint "Cover" (outside) can be Hypaion painted on special order.
 3. Standard fabric reinforcement is polyester. Other high temperature materials are available upon request.
 4. For vacuum applications, all fabric elements should retain sufficient setback from the duct to ensure that belting does not protrude into the flow stream.

	Non-Metallic Fan/Duct Connector Weight (pounds per square foot of periphery)											
Nominal				Elastomer	s			Retaining				
Body Thickness	Chloro- butyl	EPDM	Hypalon®	Neoprene/ Hypalon®	Neoprene	Neoprene/ Buna-N	Viton®	Rings/Bars Linear/Foot				
1/4"	1.6	1.6	1.8	1.8	1.8	1.8	2.5	3.5				
3/8"	3/8" 2.5 2.5 2.6 2.6 2.6 2.6 4.8											

Maximum Movement Capabilities									
6" Face To Face			9" Face To Face			12" Face To Face			
Axial Compression (Inches)	Axial Extension (Inches)	Lateral Offset (Inches)	Axial Compression (Inches)	Axial Extension (Inches)	Lateral Offset (Inches)	Axial Compression (Inches)	Axial Extension (Inches)	Lateral Offset (Inches)	
1.5	.50	.75	2.0	.75	1.5	3.75	1.0	2.5	

Lateral Offsets shown above are based on movements prior to axial compression. Greater lateral offset may be

obtained if the fan/duct connector encounters simultaneous compression.

2. Axial extension may be increased by pre-compression of the fan/duct connector during installation. any pre-compression of the fan/duct connector will equally reduce the rated axial compression movement.

1/2" DIA. Fastners (By Others) Ducting Flange (By Others) Flange Height "Standard"
Duct I.S. (I.D.) Face To Face (F/F) "Neutral Installed"
* Holes © 5/8" Dia. Round Flange Detail * 4" Max. Spacing Recommended * Bolt Circle
Rectangular Flange/ Corner Detail
1" First - * Holes @ 5/8" Dia. * 4" max. Spacing Recommended

	Design Data Sheet Fan/Duct Connector - Style 540						
ltem	Tag No.:						
lte.	Quantity:						
u	Equipment Adjacent The Connector:						
Application	Media: Gas or Air (circle one)	G A					
Ap	Location of Joint: (Inlet, Discharge, Bypass)						
Size	Duct I.S. or Diameter:						
	Face To Face:		IN.				
rature	Operating:		°F				
Temperature	Design:		°F				
Pressure	Operating:		PSI				
Pres	Design:		PSI				
Movements	Axial Compression:		IN.				
	Axial Extension:		IN.				
	Lateral Offset:		IN.D5				

SERIE\$

non-metallic flexible fan/duct connectors

Style 501: Known as a "Flat Belt Type", this non-metallic connector is primarily used for low pressure vibration applications and can be attached to existing metal frames or duct work. The PROCO Series 500, Style 501 duct connector can be manufactured in round or rectangular shapes and can be attached to metal surfaces using clamps (round applications), or backing bars (rectangular applications). The Style 501 can be manufactured in a variety of elastomers and can be sent to the field spliced endless and/or prepared for cold field splice. See Table 1 for material considerations

Style 502: Known as a "Flat Belt Arch-Type", this non-metallic connector is used for low pressure applications where movements are required and can be attached to existing metal frames or duct work. The PROCO Series 500, Style 502 duct connector can be manufactured in round or rectangular shapes and can be attached to metal surfaces using clamps (round applications), retaining rings (round applications), or backing bars (rectangular applications). The Style 502 Flat Belt Arch-Type can be manufactured in a variety of elastomers and can be sent to the field in an endless connection only. See Table 1 for material considerations.

Style 190-K: Known as a "Navy Fan Connector", the Style 190K is manufactured of 3/16" thick polyester fabric reinforced neoprene MIL-R-6855, Class 2, Durometer 40. The Style 190-K Navy Fan Connector can be manufactured in U-Type or Arch-Type forms depending upon application requirements. U-Type connectors can be manufactured with a minimum 3" face-to-face overall length. Arch-Type connectors can be manufactured with a minimum 6" face-to-face overall length. PROCO can manufacture the Series 500, Style 190-K in both round and rectangular shapes. If flange drilling is required for the Style 190-K Navy Fan Connectors, PROCO can drill per customer's specifications. Retaining rings and/or backing bars can be furnished (drilled or undrilled) upon request. See Table 1 for material considerations.

Table 1: Available Styles /Materials								
	For Specific Elastomer Recommendations, See: PROCO™ "Chemical To Elastomer Guide"							
Styles	PROCO Material Code	Elastomer	Nominal Body Thickness	No. of Reinforcement Plies	Maximum Pressure Rating (PSI)			
501	BB EE HH NH NN VV	Chlorobutyl EPDM Hypalon® Neoprene/Hypalon® Neoprene Neoprene/Buna-N Viton®	3/16" 1/4" 3/8"	1 2 2	±1 ±2 ±2			
502	BB EE HH NH NN VV	Chlorobutyl EPDM Hypalon® Neoprene/Hypalon® Neoprene Neoprene/Buna-N Viton®	3/16" 1/4" 3/8"	1 2 2	±1 ±2 ±2			
190-K	NN VV	Neoprene Viton®	3/16"	1	±2			

Hypalon and Viton are registered trademarks of DuDont Dow Elastomers

Expansion Joint "Cover" (outside) can be Hypalon painted on special order. Standard fabric reinforcement is polyester. Other high temperature materials are available upon request. For vacuum applications, all fabric elements should retain sufficient setback from the duct to ensure tha belting does not protrude into the flow stream.














Blowers & Compressors

For "Blower" and "Compressor" applications where expansion joints are required to absorb movements and vibration, please consider using the following rubber expansion joints manufactured by PROCO Products Inc. . . .

- Series 240/242 Molded Expansion Joints
- · Series RC Concentric Expansion Joints
- Series RE Eccentric Reducer Expansion Joints
- · Series 251 Molded Wide-Arch Expansion Joints

PROCO recommends that EPDM and/or Chlorobutyl (Butyl) be used for blower and compressor service. Available inventories sizes range from 1" to 30".





PROCO Series 240/242 Molded Expansion Joints for Blower Service



PROCO Series RE
Eccentric Reducer Expansion Joints
For Blower Service



PROCO Series RC
Concentric Reducer Expansion Joints
For Blower Service

Engineering Note: Non-Metallic flexible fan/duct connectors are critical to system performance. PROCO Products, Inc. encourages each specifying engineer and expansion joint user to become familiar with the F.S.A. Standards and to specify equipment designed in accordance with recommended practices. To obtain a copy of the F.S.A. Technical Handbook, write to the: Fluid Sealing Association • 2017 Walnut Street • Philadelphia, PA 19103

Speed Is Our Strength!

- Same-day shipping
- Knowledgeable sales staff that has an average of 16 years experience with expansion joints
- Daily UPS® and ROADWAY® pick-up
- Preselected freight carriers to minimize "interline transfer"

- Emergency service for nights, weekends, and even holidays
- Complete expansion joint product line
- Largest inventory in North America



2431 North Wigwam Dr. (95205) P.O. Box 590 • Stockton, CA 95201-0590 • USA



DISTRIBUTED BY:

TOLL-FREE PHONE: (800) 344-3246 FACSIMILE: (209) 943-0242 (209) 943-6088

e-mail: sales@procoproducts.com web site: http://www.procoproducts.com

NATIONWIDE AND CANADA
INTERNATIONAL