




Caps
STANDARD WEIGHT
 Inches / Pounds




Nominal Pipe Size	Outside Diameter	Inside Diameter	Wall Thickness (T)	Length (E)	Pipe Schedule	Weight in Pounds
1/2	0.84	.622	.109	1.00	40	0.08
3/4	1.05	.824	.113	1.25	40	0.14
1	1.32	1.049	.133	1.50	40	0.21
1 1/4	1.66	1.380	.140	1.50	40	0.33
1 1/2	1.90	1.610	.145	1.50	40	0.54
2	2.38	2.067	.154	1.50	40	0.8
2 1/2	2.88	2.469	.203	1.50	40	1
3	3.50	3.068	.216	2.00	40	1.7
3 1/2	4.00	3.548	.226	2.50	40	2.3
4	4.50	4.026	.237	2.50	40	2.8
5	5.56	5.047	.258	3.00	40	4.6
6	6.62	6.065	.280	3.50	40	6.9
8	8.62	7.981	.322	4.00	40	11.8
10	10.75	10.02	.365	5.00	40	20.8
12	12.75	12.00	.375	6.00	*	30.3
14	14.00	13.25	.375	6.50	30	36.5
16	16.00	15.25	.375	7.00	30	43.5
18	18.00	17.25	.375	8.00	*	57
20	20.00	19.25	.375	9.00	20	75.7
24	24.00	23.25	.375	10.50	20	101
30	30.00	29.24	.380	10.50	*	137
36	36.00	35.24	.380	10.50	*	175
42	42.00	41.24	.380	12.00	*	229
48	48.00	47.24	.380	13.50	*	350

* This size and thickness does not correspond to any pipe schedule

1. Dimensions conform to ASME B16.9 & material conforms to ASTM A-234 Grade B



Caps
EXTRA STRONG
 Inches / Pounds



Nominal Pipe Size	Outside Diameter	Inside Diameter	Wall Thickness (T)	Length (E)	Pipe Schedule	Weight in Pounds
1/2	.840	.546	.147	1.00	80	0.1
3/4	1.050	.742	.154	1.25	80	0.16
1	1.315	.957	.179	1.50	80	0.28
1 1/4	1.660	1.278	.191	1.50	80	0.48
1 1/2	1.900	1.500	.200	1.50	80	0.67
2	2.375	1.939	.218	1.50	80	0.92
2 1/2	2.875	2.323	.276	1.50	80	1.3
3	3.500	2.900	.300	2.00	80	2.1
3 1/2	4.000	3.364	.318	2.50	80	3
4	4.500	3.826	.337	2.50	80	3.5
5	5.563	4.813	.375	3.00	80	5.8
6	6.625	5.761	.432	3.50	80	9.3
8	8.625	7.625	.500	4.00	80	16
10	10.750	9.750	.500	5.00	60	26
12	12.750	11.750	.500	6.00	*	38
14	14.000	13.000	.500	6.50	*	47
16	16.000	15.000	.500	7.00	40	57
18	18.000	17.000	.500	8.00	*	78
20	20.000	19.000	.500	9.00	30	100
24	24.000	23.000	.500	10.50	*	145
30	30.000	29.000	.500	10.50	20	634
36	36.000	35.000	.500	10.50	20	913
42	42.000	41.000	.500	12.00	*	1,300
48	48.000	47.000	.500	13.50	*	1,675

* This size and thickness does not correspond to any pipe schedule

- Dimensions conform to ASME B16.9 & material conforms to ASTM A-234 Grade B